



NOTE: UPSTREAM END TO BE CAPPED.  
 FABRIC TO BE INSTALLED OVER TRENCH AFTER  
 1" STONE HAS BEEN PLACED TO A DISTANCE  
 6 INCHES ON EACH SIDE OF TRENCH.

**DRAIN TILE DETAIL**

DRAWN BY \_\_\_\_\_  
 APPROVED BY \_\_\_\_\_

FRANKLIN  
 ENGINEERING DEPT

NOT TO SCALE

figure 21