

2015 International Energy Conservation Code / Wisconsin Commercial Building Code
Division of Industry Services Wisconsin Department of Safety & Professional Services

Project Name

Energy Efficiency Worksheets (Check-mark as appropriate)

- L-1 Index Sheet - Energy Conservation
- L-2 Mandatory Controls - Locations and Types
- L-3 Lighting Schedule
- L-4 Interior Lighting Power Allowance
- L-5 Exterior Lighting Summary Worksheet
- L-6 Exterior Lighting Summary Worksheet
- L-7 Installed Exterior Lighting Allowance Worksheet

Supplemental Information:

Worksheet L-2 or similar information is required on the drawings or on a separate form for all lighting energy submittals.

Worksheets L-3 to L-7 are optional. The information may be included on the drawings, or as part of COMcheck* calculations.

Additional worksheets may be added if needed.

Per SPS 361.20(2), plans, specifications, and calculations require the original signature and seal of a Wisconsin Registered Architect, Professional Engineer, or Electrical Designer per SPS 361.31(1), or an original signature and credential identification number of the Master Electrician who designs and installs the system.

Please print name and telephone number of signer

**Ink signature and either registration
stamp or Master Electrician credential
number**

*COMcheck is a federal Department of Energy computer program that can be used to demonstrate energy conservation code compliance online. The program may be downloaded to individual computers. The most recent version of COMcheck must be used to demonstrate IECC compliance with lighting in Wisconsin.

COMcheck may be found at: <http://www.energycodes.gov/comcheck>

International Energy Conservation Code / Wisconsin Commercial Building Code Division of Industry Services Wisconsin Department of Safety & Professional Services

Mandatory Controls and Locations

<p>Mandatory Provisions Checklist</p> <p>Control Exceptions Areas designated as security or emergency areas that are required to be continuously lighted Interior exit stairways, interior exit ramps and exit passageways Emergency egress lighting that is normally off.</p> <p>Manual controls for lights shall be: Accessible to occupants Located where the controlled lights are visible, or shall identify the area served by the lights and indicate their status Exception: The control is located in a remote location for safety or security reasons. Exception: The control addresses stairways or corridors that are elements of means of egress</p> <p>Light reduction controls capable of reducing connected lighting by 50% installed. Exception: Spaces that have one luminaire with less than 100 watts Exception: Area controlled by occupancy sensor (recognized as another “approved method”) Exception: Spaces that use less than 0.6 W/sf Exception: Corridors, equipment rooms, public lobbies, electrical or mechanical rooms.</p>	<p>Automatic lighting shutoff controls are provided based on either a scheduling device or an occupant sensor. Exception: Sleeping unit Exception: Space where patient care is directly provided Exception: Spaces where automatic lighting shutoff would endanger safety or security. Exception: Lighting for continuous operation Exception: Shop and laboratory classrooms</p> <p>Spaces not exceeding 25,000 sf and are not more than one floor, are independently programmed.</p> <p>Occupant override installed on automatic time switch control device which is accessible, located so the person using the device can see the lights controlled or is annunciated, manually operated, remains on for no more than 2 hrs, controls an area not exceeding 5,000 sf. Exception: Use of captive-key override permitted to exceed 2 hours for special occupancies Exception: Special occupancies shall not exceed 20,000 sf.</p> <p>Automatic time switch incorporates an automatic holiday scheduling feature.</p> <p>Daylight zones provided with independent controls. Exception: Space has 2 or fewer light fixtures. Exception: Space is less than 250 sf. Exception: Effective aperture too small. Exception: Spaces that use less than 0.6 W/sf.</p>	<p>Either a photosensor or an astronomical time switch controls exterior lighting applications. All time switches retain programming & time setting during loss of power for a period of 10 hrs or more Exception: Lights must remain on for safety, security or eye adaptation reasons.</p> <p>Display lighting has a dedicated control independent of the controls for other lighting with the room or space</p> <p>Case lighting has a dedicated control independent of the controls for other lighting with the room or space.</p> <p>Hotel and motel sleeping units & guest suites have master control device that is capable of automatically switching off all installed luminaires and switched receptacles within 20 minutes after all occupants leave the room unless exception met</p> <p>Task lighting has control device integral to lighting device or accessible wall mounted control</p> <p>Lighting for nonvisual applications shall be provided independent control</p> <p>Lighting that is for sale or for demonstration in lighting education to be controlled by independent control</p> <p>Exit signs do not exceed 5 W per side.</p>
--	---	--

Control Location (Name and/or Room #)	Space Controlled	Control Type (Occupancy Sensor, Duel Switches, Dimmer Switch, Photosensor, Time Clock, etc)	Control Purpose (Interior Lighting Control, Light Reduction, Automatic Shut-Off, Daylight Zone, Display, etc)

International Energy Conservation Code / Wisconsin Commercial Building Code
 Division of Industry Services Wisconsin Department of Safety & Professional Services

Lighting Schedule

A	B	C	D	E	F
Fixture ID	Luminaire Description including Fixture Type, Lamp, Wattage per lamp, Ballast*	Lamps/ Fixture	# of Fixture	Fixture Watts	D x E
				TOTAL = Watts	

International Energy Conservation Code / Wisconsin Commercial Building Code

Division of Industry Services Wisconsin Department of Safety & Professional Services

Interior Lighting Power Allowance IECC C405.4.2(1) based on the Building Area Method

Note: If using ASHRAE 90.1-2013, allowable watts/sq ft will vary. Use ASHRAE 90.1 - Table Section 9.5.1 and revise as needed depending on use of Building Area Method or Space-by-Space Method.

A	B	C	D
Building Area Type	Watts/ft²	Area (sq. ft)	Allowed Watts
Automotive Facility	0.80		
Convention Center	1.01		
Court House	1.01		
Dining: Bar Lounge/Leisure	1.01		
Dining: Cafeteria/Fast Food	0.90		
Dining: Family	0.95		
Dormitory	0.57		
Exercise Center	0.84		
Fire station	0.67		
Gymnasium	0.94		
Healthcare-Clinic	0.90		
Hospital	1.05		
Hotel/Motel	0.87		
Library	1.19		
Manufacturing Facility	1.17		
Motion Picture Facility	0.76		
Multi-Family	0.51		
Museum	1.02		
Office	0.82		
Parking Garage	0.21		
Penitentiary	0.81		
Performing Acts Theater	1.39		
Policed station	0.87		
Post Office	0.87		
Religious Building	1.00		
Retail	1.26		
School/University	0.87		
Sports Arena	0.91		
Town Hall	0.89		
Transportation	0.70		
Warehouse	0.66		
Workshop	1.19		
TOTALS			

Ft² Area

Watts

Total Allowed Interior Power Allowance _____ W > Proposed Interior Lighting _____ W

International Energy Conservation Code / Wisconsin Commercial Building Code
 Division of Industry Services Wisconsin Department of Safety & Professional Services

Exterior Lighting Power Allowance IECC C405.5.1

**TABLE C405.5.1(1)
 EXTERIOR LIGHTING ZONES**

INDICATE LIGHTING ZONE	DESCRIPTION
<input type="checkbox"/> 1	Developed areas of national parks, state parks, forest land, and rural areas.
<input type="checkbox"/> 2	Areas predominantly consisting of residential zoning, neighborhood business districts, light industrial with limited nighttime use and residential mixed use areas.
<input type="checkbox"/> 3	All other areas
<input type="checkbox"/> 4	High-activity commercial districts in major metropolitan areas as designated by the local land use planning authority

**TABLE C405.5.1(2)
 INDIVIDUAL LIGHTING POWER ALLOWANCES FOR BUILDING EXTERIORS**

		Zone 1	Zone 2	Zone 3	Zone 4
Base Site Allowance (Base allowance may be used in tradable or nontradable surfaces.)		500 W	600 W	750 W	1300 W
Tradable Surfaces (Lighting power densities for uncovered parking areas, building grounds, building entrances and exits, canopies and overhangs and outdoor sales areas may be traded.)	Uncovered Parking Areas				
	Parking areas and drives	0.04 W/ft ²	0.06 W/ft ²	0.10 W/ft ²	0.13 W/ft ²
	Building Grounds				
	Walkways less than 10 feet wide	0.7 W/linear foot	0.7 W/linear foot	0.8 W/linear foot	1.0 W/linear foot
	Walkways 10 feet wide or greater, plaza areas special feature areas	0.14 W/ft ²	0.14 W/ft ²	0.16 W/ft ²	0.2 W/ft ²
	Stairways	0.75 W/ft ²	1.0 W/ft ²	1.0 W/ft ²	1.0 W/ft ²
	Pedestrian tunnels	0.15 W/ft ²	0.15 W/ft ²	0.2 W/ft ²	0.3 W/ft ²
	Building Entrances and Exits				
	Main entries	20 W/linear foot of door width	20 W/linear foot of door width	30 W/linear foot of door width	30 W/linear foot of door width
	Other doors	20 W/linear foot of door width	20 W/linear foot of door width	20 W/linear foot of door width	20 W/linear foot of door width
	Entry canopies	0.25 W/ft ²	0.25 W/ft ²	0.4 W/ft ²	0.4 W/ft ²
	Sales Canopies				
Free-standing and attached	0.6 W/ft ²	0.6 W/ft ²	0.8 W/ft ²	1.0 W/ft ²	

International Energy Conservation Code / Wisconsin Commercial Building Code
 Division of Industry Services Wisconsin Department of Safety & Professional Services

TABLE C405.5.1(2) Continued

Tradable Surfaces	Outdoor Sales				
	Open areas (including vehicle sales lots)	0.25 W/ft ²	0.25 W/ft ²	0.5 W/ft ²	0.7 W/ft ²
Street frontage for vehicle sales lots in addition to "open area" allowance	No allowance	10 W/linear foot	10 W/linear foot	30 W/linear foot	
Non-Tradable Surfaces (Lighting power density calculations for the following applications can be used only for the specific application and cannot be traded between surfaces or with other exterior lighting. The following allowances are in addition to any allowance otherwise permitted in the "Tradable Surfaces" section of this table.)	Building facades	No allowance	0.075 W/ft ² of gross above-grade wall area	0.113 W/ft ² of gross above-grade wall area	0.15 W/ft ² of gross above-grade wall area
	Automated teller machines (ATM) and night depositories	270 W per location plus 90 W per additional ATM per location	270 W per location plus 90 W per additional ATM per location	270 W per location plus 90 W per additional ATM per location	270 W per location plus 90 W per additional ATM per location
	Entrances and gatehouse inspection stations at guarded facilities	0.75 W/ft ² of covered and uncovered area	0.75 W/ft ² of covered and uncovered area	0.75 W/ft ² of covered and uncovered area	0.75 W/ft ² of covered and uncovered area
	Loading areas for law enforcement, fire, ambulance and other emergency service vehicles	0.5 W/ft ² of covered and uncovered area	0.5 W/ft ² of covered and uncovered area	0.5 W/ft ² of covered and uncovered area	0.5 W/ft ² of covered and uncovered area
	Drive-up windows/doors	400 W per drive-through	400 W per drive-through	400 W per drive-through	400 W per drive-through
	Parking near 24-hour retail entrances	800 W per main entry	800 W per main entry	800 W per main entry	800 W per main entry

Tradable Exterior Lighting Power Allowance IECC C405.5.1(2)

A	B	C	D
Tradable Surfaces Area Description	Allowance [Table C405.5.1(2)]	Area or Linear Feet in Proposed Design	Total (B X C)
Total Watts			

International Energy Conservation Code / Wisconsin Commercial Building Code
 Division of Industry Services Wisconsin Department of Safety & Professional Services

Non-Tradable Exterior Lighting Power Allowance IECC C405.5.1(2)

A	B	C	D
Non-Tradable Surfaces Area Description	Allowance [Table C405.5.1(2)]	Area or Linear Feet in Proposed Design	Total (B X C)
Total Wattage			

Tradable Installed Exterior Lighting Power IECC C405.5.1

A	B	C	D
Fixture Type	Number of Luminaires Installed	Watts per Luminaire (including ballast)	Installed Watts (B X C)
Total Watts			

Total Allowed Exterior Power Allowance _____W > Proposed Exterior Lighting _____W

Forms for use with ASHRAE 90.1-2013 as allowed by IECC C401.2 Item 1, may be substituted for the forms indicated above.