

**OWNER'S ACKNOWLEDGEMENT OF CONDITIONS FOR FENCES LOCATED IN  
WE ENERGIES UTILITY EASEMENTS**

Fences may be permitted in We Energies utility easements only subject to the following:

1. The fence shall not be positioned nearer than 3' to any side of a transformer if present.
2. The fence shall not be positioned nearer than 10' to the door of any transformer if present.  
***EXCEPTION:** If a gate or easily removable section of fence is positioned directly in front of the door and measures at least as wide as the door to the transformer, the distance may be reduced to 3'.*
3. We Energies will not repair or replace any portion of the fence in the utility easement if the fence needs to be removed for any utility work including clearing obstructions in the easement area.
4. The fence shall not be attached to any utility equipment.
5. "Digger's Hotline" shall be contacted prior to any excavation work.
6. This authorization only applies to We Energies utility easements.

Property Owner(s) hereby acknowledges that he/she has read and understands the above conditions:

Sign \_\_\_\_\_ Print \_\_\_\_\_

Sign \_\_\_\_\_ Print \_\_\_\_\_

**NOTE: The owner must sign this acknowledgement and include it with their fence permit submittal.**